

PROFORMA FOR SAGE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 18/07/2026

It is certified that an inspection team headed by Dr. Kapil Garg (Medical Superintendent)(Name of Officers with designation) from C.H.C. CSE Hapur PHEDInspected the Delhi City School, Simrauli, Hapur (UP) (Name & Address of the School) on 18/07/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. TC-12418 dated 14/07/2026 ofD.L.W.A.L. UP JAL Nigam (Rural) Hapur (PHED LAB) certified that theDelhi City School (Name of School) has safe drinking water facilities for the students and members of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.The certificate is valid till 1 year

Signature with Seal:

Name:

Designation:

Name & Address of the Deptt. /Office:

To,

The Chairman,Delhi City School, Simrauli, Hapur (UP)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/Local Bodies.

Garg
Chairman
Delhi City School
NH-09 Simrauli Hapur (U.P.)

Garg
Chairman
Delhi City School
Simrauli, Hapur (U.P.)

Principals
Principal
Delhi City School
NH-09 Simrauli Hapur (U.P.)



District Level Water Analysis Laboratory Uttar Pradesh Jal Nigam , Rural , Hapur (245101)

Test Report



TC-12418

14/07/2026

Test Report No.	UPJN/HPU/610	Issue Date	14/07/2026
		Location of Testing	Laboratory District Lab Hapur

Customer's Name	DELHI CITY SCHOOL ,BABURAGH ,HAPUR
Address	DELHI CITY SCHOOL ,BABURAGH CANTT , ,HAPUR


Sampling Method : UPJN(R)QSP/02/2.9	Sample Description -- Drinking Water
-------------------------------------	--------------------------------------

Basic Details of Sample			
Quantity of Sample	1 Lit.	Sample ID	UPJN/HPU/610
Condition of Sample	Plastic Bottle (at Room Temp)	Location of Sampling	DELHI CITY SCHOOL ,BABURAGH CANTT , ,HAPUR
Type of Source	R.O. water		
District	HAPUR	Block	Hapur
Gram Panchayat	BABUGARH	Village	BABUGARH
Sampling Date	13/07/2026	Sampling Done By	RAHUL KUMAR
Analysis Start Date	13/07/2026	Analysis Completion Date	14/07/2026
Temperature: 25±2 °C		Relative Humidity	50±15%

Technical Data of Analysis						
S. No.	Test parameters	Unit of Measurement	Observed Value	Specific requirements as per IS 10500		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH at 25°C	-	7.02	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2022
2	Turbidity	NTU	0.79	1	5	IS 3025 (Part 10): 2023
3	Total Dissolved Solids	mg/L	66	500	2000	IS 3025 (Part 16): 2023
4	Chloride (as Cl)	mg/L	24	250	1000	IS 3025 (Part 32): 2019
5	Total alkalinity (as CaCO ₃)	mg/L	96	200	600	IS 3025 (Part 23): 2023
6	Total hardness (as CaCO ₃)	mg/L	72	200	600	IS 3025 (Part 21): 2019
7	Calcium (as Ca)	mg/L	16	75	200	IS 3025 (Part 40): 2023
8	Magnesium (as Mg)	mg/L	7.76	30	100	IS 3025 (Part 46): 2023

1. This Test Report only to the particular sample(s) submitted for Analysis.
2. This Test Report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of
3. The test results reported in this Test Report are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Water Sample is not Collected by us.

Prepared by



Format No. HPU 7.8.2/1 (Rev. 1)

*** End of Test Report ***

Chairman

Delhi City School

NH-09 Simrauli Hapur (UP)

Principal

Delhi City School

NH-09 Simrauli Hapur (UP)